

## **GENERAL NOTES:**

- 1. Provide insulation and finish systems to meet EIMA Specifications. Installation of insulation and finish system shall be in accordance to EIMA's Guide to Exterior Insulation & Finish System Construction.
- 2. Provide air/water barrier compatible to EIFS. Air/water barrier to be continuous from face of exterior wall over parapet, and to structural roof decking. Air/Water Barrier type and location shall be in accordance with the NRCA Roofing and Waterproofing Manual.
- 3. Check with Underwriters Laboratories for specific air/water barrier systems.
- 4. Face of coping shall extend a minimum of 2-1/2" below edge of EIFS.
- 5. Follow SFIA Technical Guide for Cold-Formed Steel Framing Products for specific depth, thickness, and spacing of structural studs and roof joists.
- 6. Consult with specialty structural engineer for structural stud and roof design.
- 7. Check local codes and mechanical engineer for vapor type and location.

DISCLAIMER: This detail must not be used without a complete evaluation by the owner's design professional to verify validity of the design.



NOT TO SCALE